

Annual Drinking Water Quality Report for 2017
Saranac Water District
PO Box 147, Saranac, NY 12981
(Public Water Supply ID# NY 0900225)

Introduction

To comply with State regulations, Saranac Water District will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerning your drinking water, please contact Martha Chase at (518) 735-4666, or Nick Carter, Town Supervisor, at 293-6666. We want you to be informed about your drinking water.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves about 90 people through 48 service connections. Our water source is an infiltration gallery, which is located on Lavarney Lane. The water is filtered and chlorinated prior to distribution. The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from an infiltration gallery. The source water assessment has rated our source as having a high susceptibility to microbials and nitrates. These ratings are due primarily to the close proximity of permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) in relation to our source. The report has also rated our source as having a medium-high susceptibility to halogenated solvents, herbicides/pesticides, metals, industrial organics, petroleum products, and protozoa. These ratings were given because the water is drawn from an area with fractured bedrock and the overlying soils do not provide adequate protection from potential contamination. Please note that, while the source water assessment rates our infiltration gallery as being susceptible to microbials, our water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination. A copy of this assessment, including a map of the assessment area, can be obtained by contacting us, as noted above.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: Total coliform, Turbidity, Nitrate, Lead and Copper, Gross Alpha Particle Activity, Primary Inorganic Chemicals, Disinfection By-products (Total Trihalomethanes and Haloacetic Acids), Principal Organic Chemicals, Synthetic Organic Chemicals, and Radium 226 and 228. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Clinton County Health Department at (518) 565-4870.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Lead (1)	No	8/21/17	90 th =1.3 Range-BRL-1.5	ug/l	0	AL=15	Corrosion of Household plumbing
Copper (1)	No	8/21/17	90 th =0.16 Range-0.061 to 0.19	mg/l	1.3	AL=1.3	Corrosion of household plumbing, erosion of natural deposits.
Total Trihalomethanes (TTHM)	No	9/18/17	5.5	ug/l	N/A	MCL=80	By-product of drinking water disinfection needed to kill harmful organisms.
Total Haloacetic Acids (HAA5)	No	9/18/17	3.2	ug/l	N/A	MCL=60	By-product of drinking water disinfection needed to kill harmful organisms.
Chloroform	No	5/30/17	1.5	ug/l	N/A	80	By-product of drinking water disinfection.
Bromodichloro-methane	No	5/30/17	0.5	ug/l	N/A	80	By-product of drinking water disinfection.
Nitrate	No	4/28/17	0.06	mg/l	10	10	Runoff from fertilizer use, leaching from septic tanks.
Barium	No	5/30/17	6.2	ug/l	2000	MCL=2000	Erosion of natural deposits, discharge from drilling waste.
Turbidity	No	Daily	Avg=0.21 Range=0.17 to 0.31	NTU	N/A	TT=<1.0	Soil runoff
Total Coliform (2)	No	9/20/17	present	Present or absent	absent	present	Naturally present in the environment
Radiological Contaminants							
Gross Alpha Particles	No	05/30/17	0.351	pCi/l	N/A	15	Erosion of natural deposits
Combined Radium - 226 and 228 (3)	No	05/30/17	0.594	pCi/l	N/A	5 (3)	Erosion of natural deposits

Notes:

1 – The level presented represents the 90th percentile of the sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case samples were collected and the 90th percentile was the average of the 1stth and 2nd highest samples. The action levels for lead and copper were not exceeded at any of the sites tested.

2- This sample was present for total coliform, additional samples were collected as follow up and no contamination was detected.

3 – MCL is for combined radium 226 and 228.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water

system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb)

Nephelometric Turbidity Unit (NTU): -A measure of the clarity of water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no MCL violations. We have learned through our testing that some other contaminants have been detected; however, these contaminants were detected below the level allowed by the State. If present, elevated level of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. Saranac Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 3 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. A water sample in September tested positive for total coliform, but required follow up samples revealed no contamination. We had a water main break in June, which was repaired and no contamination detected. Additionally, our system continues to be out of compliance with the requirement to implement our Cross Connection Control Program.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.